



Jim Doyle, Governor
Mary P. Burke, Secretary

January 9, 2007

LEDGEVIEW PRECAST CONCRETE, INC.
ALLEN E. FREUND
N6672 COUNTY TRUNK UU
FOND DU LAC WI 54935

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: LEDGEVIEW PRECAST CONCRETE, INC.
Product Name: BIO-MICROBICS MICRO FAST 0.5, 0.75, 0.9, 1.5 OR HIGH STRENGTH FAST 1.0 OR 1.5
Model Number(s): 2000 S
Product File No: 20070002

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of January 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

This approval supersedes the approval issued on 09/04/2003 under product file number 20030413. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030413.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov